

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-0078:157 Page 1 of 1

CATEGORY: Control Units (Household)

LISTEE: ADEMCO, 165 Eileen Way, Syosset NY 11791
Contact: David Kalmus (516) 921-6704

DESIGN: Models 4110DL, 4110XM, Vista-10SE, Via-30PSE*, SAVS10SE* and SA10ADTE* fire alarm control units. Power-limited. Refer to listee's data sheet for detailed product description and operational considerations. System components:

4229	Expander/Relay Module
4204	Relay Module
4219	Zone Expander
4127/4137/5333/5137	Remote Consoles

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as household fire alarm control units for use with the following accessories: Models 5700 and 5800 Series photoelectric smoke detectors (CSFM Listing No. 7272-0078:152), System Sensor Model PA400B remote signal sounder (CSFM Listing No. 7135-1209:143).

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1993 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: Formerly 7165-0078:157

*Rev. 04-23-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 8, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager